



fundamental laws of electrical circuit analysis. It is as follows:

“Solution: Let us write the Kirchoff’s current law for each node (bus) of Fig. 7.2 and assume that the sum of the currents away from the bus is equal to zero. That is, for the buses 1-3, we have

$$\begin{aligned} (v_1 - v_2)y_{12} - I_1 &= 0 \\ (v_1 - v_2)y_{12} + (v_2 - v_3)y_{23} + I_2 &= 0 \\ (v_3 - v_4)y_{23} + I_3 &= 0 \end{aligned} \quad (1)$$

where  $y_{12} = 1/Z_{1-2}$ ,  $y_{23} = 1/Z_{2-3}$ , and

$$I_1 = \left(\frac{S_1}{V_1}\right)^*, \quad I_2 = \left(\frac{S_2}{V_2}\right)^*, \quad I_3 = \left(\frac{S_3}{V_3}\right)^* \quad (2).”$$

After substitution, the author comes forward with the following:

“The above can be written as

$$\begin{bmatrix} Y_{11} & Y_{12} & 0 \\ Y_{21} & Y_{22} & Y_{23} \\ 0 & Y_{32} & Y_{33} \end{bmatrix} \begin{bmatrix} V_1 \\ V_2 \\ V_3 \end{bmatrix} = \begin{bmatrix} I_1 \\ I_2 \\ I_3 \end{bmatrix}, \quad (3)$$

where  $Y_{11} = y_{12}$ ,  $Y_{12} = -y_{12}$ ,  $Y_{21} = -y_{12}$ ,  $Y_{22} = y_{12} + y_{23}$ ,  $Y_{23} = -y_{23}$ ,  $Y_{32} = -y_{23}$  and  $Y_{33} = y_{23}$ . The matrix equation (3) represents the bus admittance matrix; it is also the  $Y_{\text{Bus}}$  model for Example 7.2.”

Equation (3) in fact is not a final solution. It can’t be, and we will come back to that. To come to the final, the authors in [3] and [4] turn from voltages and currents into power by creating nonlinear equations describing a linear system. These, naturally, need special algorithms in order to be solved (Gauss-Seidel is advised first). That includes creating initial solutions and control of convergence. In [5] Newton-Raphson is further recommended due to its faster convergence.

### III. MODIFIED NODAL ANALYSIS

Nodal analysis (NA) is based on the Kirchoff’s current law and as it is already explained above the node equations is expressing the following: The sum of currents leaving the node is equal to zero. The node voltages are unknown while the currents are first expressed as functions of node voltages using the constitutive equations of the circuit elements connected to a node. Frequency domain analysis is facing a problem when ideal voltage source is connected between nodes since the branch current cannot be expressed as a function of the branch voltage (ideal voltage source has no Norton equivalent). Time domain analysis, in addition, has problem to express the voltage equation of the

inductance. Both problems are solved when Modified Nodal Analysis (MNA) is implemented [6,7]. The trick is that the branch current of the voltage element (ideal voltage source or inductor) is introduced as a new variable enabling the proper node equations to be assembled. In that way the number of variables is incremented by 1. In addition, the system of circuit equations is extended by a new equation related to the branch of the voltage element. Fig. 1 depicts an ideal voltage source connected between nodes  $j$  and  $k$ , and the “stamp” or the contribution of such an element to the system of equations describing the circuit.

Implementation of MNA is not domain dependent. This means that one uses the same concept for (power-) frequency and the time domain analysis [8], while the system to be analyzed may be linear or nonlinear. To our knowledge there are serious attempts within the power electrical engineering community to adopt MNA and implement it for system simulation [5,8-13]. That is not the case for the LFA as it is thought at universities and hence our intervention.

Node	$v_j$	$v_k$	$i_{\text{new}}$
$j$			1
$k$			-1
New equation	1	-1	E




Fig. 2. An ideal voltage source connected between nodes  $j$  and  $k$ , and the “stamp” or the contribution of such an element to the system of equations describing the circuit.

### IV. LOAD FLOW ANALYSIS VERSUS MODIFIED NODAL ANALYSIS

We will start here to express our full disagreement with developments expressed in second section. To begin with, the node voltage  $V_1$  is already known and one should not expect that the solution of (3) would produce the same value as the original. Then, node 1 (bus bar 1) has no internal impedance which is easily recognized from the fact that  $S_1$  is missing in Fig. 2. That may look as unimportant mistake but in fact is a fundamental error misleading the whole analysis. As already mentioned ideal voltage source has no Norton equivalent meaning that  $I_1$  cannot be related to  $V_1$ . The bus bar current is unknown until the end of the analysis since it depends on the load. Theoretically, for the same bus bar voltage, it may vary from zero to infinity. If, however, the ideal voltage source was to be kept in the circuit it would be impossible to formulate the nodal equations as above. One would need to use MNA by which

$I_1$  would be introduced as unknown circuit variable and the order of the system of equations would be raised by 1.

Further, equation (2) is also misleading. Namely, a set of unknown variables ( $V_i, i = 1, 2, 3$ ) is used to create a set of other unknown variables ( $E_i, i = 1, 2, 3$ ) while both stay in the same system. According to the author, to get the “ $Y_{\text{Bus}}$  model” one should create a system of three equations with six unknowns. That is difficult to believe, and as already commented it leads nowhere. Furthermore, if the node voltages change why would the load power stay constant? Namely, the truth is  $\mathbf{S}$ , as given in the figure, are *nominal powers* which, for the given impedances are valid only for the *nominal voltages*. The load impedance is the only invariant (since steady load is presumed). In our opinion the loads were to be noted as nominal ( $\mathbf{S}_N$ ) being valid only for nominal voltages ( $\mathbf{V}_N$ ) and used to find the admittances only.

To put the same comment in other words, if  $\mathbf{I}$  is unknown (since  $\mathbf{V}$  is unknown), why are they on the right-hand side of the equation? Or, how many complex valued unknowns are in (2) and (3), three, six or nine?

Unfortunately, the story does not end here. Namely, looking at the final “ $Y_{\text{Bus}}$  model” and switching off the source (putting  $I_1 = 0$ ) one gets

$$\begin{bmatrix} Y_{11} & Y_{12} & 0 \\ Y_{21} & Y_{22} & Y_{23} \\ 0 & Y_{32} & Y_{33} \end{bmatrix} \begin{bmatrix} V_1 \\ V_2 \\ V_3 \end{bmatrix} = \begin{bmatrix} 0 \\ I_2 \\ I_3 \end{bmatrix} \quad (4)$$

or

$$\mathbf{Y} \cdot \mathbf{V} = \begin{bmatrix} 0 \\ I_2 \\ I_3 \end{bmatrix}, \quad (5)$$

whose solution is

$$\mathbf{V} = \mathbf{Y}^{-1} \cdot \begin{bmatrix} 0 \\ I_2 \\ I_3 \end{bmatrix} \neq \mathbf{0}. \quad (6)$$

Can the grid produce node voltages even if there is no power source active in it?

Here we come to one of the fundamental mistakes done when loads are represented in LFA (and not only in it). Namely, instead of impedances (which are in fact the loads) one uses current sources. However, a current source is a *source of energy* even if it is negative by value while the impedance is a *consumer of energy*. Interchanging those leads to wrong solutions (like, having voltages and currents in absence of real sources in the system).

Furthermore, looking in circuit theoretical mode, the impedance's current changes linearly with the change of its voltage. The current of a current source is constant and independent of the voltages drop on it (looking at it as if it is impedance, it becomes nonlinear conductance with hyperbolic decay). Finally, by use of a constant current source we ignore any change of the currents in all loads. So, since we know the currents ( $\mathbf{I}$ ) and the loads ( $\mathbf{S}$ ), there is no need for any analysis. The voltages may be obtained from (2) backwards.

To conclude, both node voltages and load currents (and consequently load powers) are unknown at the beginning of the analysis and the concept expressed in [3,4] is misleading.

One is not to forget that the books we are speaking about ([3] had two and [4] eight editions) are intended to be read by novices (students).

Before proceed to implementation of the MNA as an ultimate solution of the equation formulation problem we will try to accommodate to the NA. Of course, we will suppose that  $\mathbf{V}_N$  and  $\mathbf{S}_N$  are known which means we know the load admittances  $Y_{L2}$  and  $Y_{L3}$ .

Supposing  $I_1$  is known, one is to substitute the admittances of the loads and proceed with the formulation in the form

$$\begin{bmatrix} Y_{11} & Y_{12} & 0 \\ Y_{21} & Y_{22} & Y_{23} \\ 0 & Y_{32} & Y_{33} \end{bmatrix} \begin{bmatrix} V_1 \\ V_2 \\ V_3 \end{bmatrix} = \begin{bmatrix} I_1 \\ 0 \\ 0 \end{bmatrix}, \quad (7)$$

where  $Y_{11} = y_{12}$ ,  $Y_{12} = Y_{21} = -y_{12}$ ,  $Y_{22} = y_{12} + y_{23} + Y_{L2}$ ,  $Y_{23} = -y_{23}$ ,  $Y_{32} = -y_{32}$  and  $Y_{33} = y_{23} + Y_{L3}$ .

Again,  $Y_{L2}$  and  $Y_{L3}$  are the admittances of the loads which are passive and do not generate energy (hence, must be on the left-hand side of the equation).

Since  $V_1$  (not  $I_1$ ) is known, by simple manipulations one gets

$$\begin{bmatrix} -1 & Y_{12} & 0 \\ 0 & Y_{22} & Y_{23} \\ 0 & Y_{32} & Y_{33} \end{bmatrix} \begin{bmatrix} I_1 \\ V_2 \\ V_3 \end{bmatrix} = \begin{bmatrix} -Y_{11}V_1 \\ -Y_{21}V_1 \\ 0 \end{bmatrix}. \quad (8)$$

This seems an acceptable final solution. It resembles the case when the admittance of the first line,  $Y_{11} = 1/Z_{1-2}$ , is used as internal admittance of the voltage source  $V_1$ . This (handmade) trick is, unfortunately, not applicable when more than one line is connected to the bus bar.

In other words, we would prefer a universal method

enabling in the same time for automatic (computer generated) equation formulation. Here comes the MNA. If MNA was to be applied instead (7) one would have:

$$\begin{bmatrix} Y_{11} & Y_{12} & 0 & -1 \\ Y_{21} & Y_{22} & Y_{23} & 0 \\ 0 & Y_{32} & Y_{33} & 0 \\ 1 & 0 & 0 & 0 \end{bmatrix} \begin{bmatrix} V_1 \\ V_2 \\ V_3 \\ I_1 \end{bmatrix} = \begin{bmatrix} 0 \\ 0 \\ 0 \\ E_g \end{bmatrix} \quad (9)$$

Here a voltage source ( $E_g$ ) is connected to node 1. This system complies with the equation formulation used in the SPICE program [12,14] meaning that if SPICE description were created one would produce the solution in no time. Note there are versions of SPICE available for free.

To finalize, one is not to forget that when all node (or branch) voltages are known we may calculate *everything*: currents and powers, meaning there is no need to switch to powers before the node voltages are found.

## V. CONCLUSION

To conclude, it is our opinion that it is time to demystify the power system analysis (including PFA) as taught until now, since despite of a very long period of use of such systems is still obscure and ineffective. Using a simple, but as general as necessary, example we showed that MNA should be taught to our student as a universal means of equation formulation for circuits and systems simulation.

## ACKNOWLEDGEMENT

This research was partly funded by The Ministry of Education, Science and Technical Development of Republic of Serbia under contract No. TR32004.

## REFERENCES

- [1] Dimitrijević, M., Milojković, J., Bojanić, S., Nieto-Taladriz, O. and Litovski, V. (2013), "ICT and power: new challenges and solutions", *International Journal of Reasoning-based Intelligent Systems*, Vol. 5, No. 1, pp. 32-41., doi:10.1504/IJRIS.2013.0.
- [2] Bellosta, L.C.M., et al. (1998), "Simulation of Surges on Power Lines Using SPICE and EMTP: A Comparative Study", in *Proceedings of the 9th Mediterranean Electrotechnical Conference in Tel-Aviv, Israel, 1998*, Institute of Electrical and Electronics Engineers, pp. 202-206, doi: 10.1109/MELCON.1998.692371.
- [3] Keyhani, A. (2016), *Design of Smart Power Grid Renewable Energy Systems*, Wiley-IEEE Press, New York, USA, second edition.
- [4] Weedy, B.M., Cory, B.J., Jenkins, N., Ekanayake, J.B. and Strbac, G. (2012), *Electric Power Systems*, John Wiley & Sons Ltd, New Jersey, USA, Fifth Edition.
- [5] Vergura, S., Liserre, M. and Vacca, F. (2007), "Adjoint Network Theory to Analyse the Power Converters with Respect to their Line-side Behaviour", in Lattarulo, F. (Ed.), *Electromagnetic compatibility in power systems*, Elsevier Science, Amsterdam, Netherlands.
- [6] Ho, C.W., Ruehli, A. and Brennan, P. (1975), "The Modified Nodal Approach to Network Analysis", in *Proceedings 1974 Int. Symp. on Circuits and Systems in San Francisco, USA, 1975*, Vol. 22, No. 6, Institute of Electrical and Electronics Engineers, pp. 504-509, doi: 10.1109/TCS.1975.1084079.
- [7] Litovski, V. and Zwolinski, M. (1997), *VLSI Circuit Simulation and Optimization*, Chapman and Hall, London, United Kingdom.
- [8] Lattarulo, F. (2007), *Electromagnetic compatibility in power systems*, Elsevier, Amsterdam, Netherlands.
- [9] Hsu, Y.C. (2010), "Design, Modeling and Validation of Permanent Magnet Generators for Wind Turbines", Department of System and Naval Mechatronic Engineering, Taiwan.
- [10] Hsu, Y.C., Hsieh, M.F. and McMahon, R.A. (2009), "A General Design Method for Electric Machines Using Magnetic Circuit Model Considering the Flux Saturation Problem", in *Proceedings of the Eighth Int. Conf. on Power Electronics and Drive Systems in Taipei, Taiwan, 2009*, Institute of Electrical and Electronics Engineers, pp. 625-630, doi: 10.1109/PEDS.2009.5385860.
- [11] Kato, S., Hoshi, N. and Oguchi, K. (2004), "Brushless slip-power recovery system simulation using modified nodal approach", *IEEJ Trans. IA*, Vol. 124, No. 12, pp. 1252-1260, doi: 10.1541/ieejias.124.1252.
- [12] Hsieh, M. and Hsu, Y. (2012), "A Generalized Magnetic Circuit Modeling Approach for Design of Surface Permanent Magnet Machines", *IEEE Transactions on Industrial Electronics*, Vol. 59, No. 2, pp. 779 - 792, doi: 10.1109/TIE.2011.2161251.
- [13] Thomas, R., Lahaye, D.J.P., Vuik, C. and Van Der Sluis, L. (2013), "Transients in Power Systems: A Literature Survey", Reports of the Department of Applied Mathematical Analysis, Delft University of Technology, Delft, Report 13-12, uuid: f30d85e1-3349-4a52-8e74-53bddca50d91.
- [14] Nagel, L. W. (1975), "SPICE2: A Computer Program to Simulate Semiconductor Circuits", EECS Dept. Uni. of California, Berkeley, Tech. Report No. UCB/ERL M520